



NOTES:

1. CONSUMER CONDUCTOR TAILS MUST BE A MINIMUM OF 24" IN LENGTH IN ORDER TO FORM DRIP LOOP
2. GUY & ANCHOR TO BE INSTALLED ON ALL SERVICES GREATER THAN 75' OR ON SERVICES LESS THAN 75' AS DETERMINED BY THE COOPERATIVE
3. GUY & ANCHOR TO BE POSITIONED IN-LINE BUT OPPOSITE OF THE PULL OF THE SERVICE WIRE
4. U-BOLT CLAMPS OR APPROVED CONNECTORS MUST BE USED ON GUY WIRE
5. NO MORE THAN 6" OF THE THIMBLE EYE AND ANCHOR ROD ABOVE GRADE
6. 8' WHITE OR YELLOW PLASTIC MARKER ATTACHED TO GUY IF EXPOSED TO TRAFFIC
7. IF SERVING A MOBILE HOME, NEC REQUIRES THAT THE SERVICE POLE BE NO MORE THAN 30' FROM THE EXTERIOR WALL OF THE MOBILE HOME
8. NESC REQUIRES ALL METER POLES TO BE NO CLOSER THAN 5' TO ANY BUILDING OR STRUCTURE
9. ITEMS MARKED WITH AN ASTERISK (*) ARE TO BE INSTALLED BY THE CONSUMER / ELECTRICIAN
10. DRAWING NOT TO SCALE

ADDITIONAL NOTES:

1. SOME SPECIFICATIONS ON THIS PAGE REPRESENT MINIMUM STANDARDS. LOCAL CODES MAY CALL FOR ADDITIONAL OR MORE STRINGENT REQUIREMENTS. CUSTOMER / ELECTRICIAN MUST ENSURE COMPLIANCE WITH ALL APPLICABLE CODES GOVERNING ELECTRICAL SERVICE.
2. NATIONAL ELECTRICAL SAFETY CODE (NESC) REQUIREMENTS PROHIBIT CONSUMERS FROM WORKING CLOSER THAN 12" OF ENERGIZED SATILLA REMC CONDUCTORS OR INSTALLING ANY EQUIPMENT WITHIN 12" OF SATILLA REMC OVERHEAD CONDUCTORS.
3. NATIONAL ELECTRICAL CODE (NEC) REQUIRES ALL CONDUCTORS ENTERING OR EXITING A METER BASE OR A CONSUMER'S DISCONNECT TO "BE PROTECTED AGAINST PHYSICAL DAMAGE." THEREFORE, ALL EXTERIOR CONDUCTORS SHOULD BE INSTALLED IN SUITABLE CONDUIT.

SATILLA REMC

METER POLE INSTALLATION

SATILLA REMC

Dwg date :
12/08/16

Effective date :
12/08/16

M25-5